



Uniform Fire Code
Administrative Ruling / Interpretation

Code Section: 7902.2.8.1 Exception number 2

Code Edition: 1997

Date: September 18, 2000

Statement of Need:

Stationary above ground tanks used outside of buildings are required to have secondary containment (RCDG 20E.100.10-040 #19) which is provided through drainage control and diking. The UFC allows local AHJ's the ability to accept listed tanks constructed with an integral method of secondary containment to meet the requirements of drainage control and diking. This ruling is written to clarify the listed tanks that Redmond Fire will recognize as providing the required secondary containment.

Ruling/Interpretation:

The following listed tanks are recognized as providing the required drainage control and diking in 7902.2.8.1 exception number 2:

UL142 with secondary containment
UL2085 with secondary containment

Robert Lovett
Fire Marshal